

PlusConnect™ BDI DPS-100D

Installation and Operation Manual



Table of Contents

Introduction.....	1
Compatibility	2
PlusConnect Compatibility	2
ARC Plus Compatibility	2
Unpacking.....	2
Front Panel Indicators.....	2
Hardware Configuration	3
SNMP Parameters.....	5
Setting the Password.....	5
Uploading New Firmware.....	5
Installation	7
Software Configuration	7
Adding the PlusConnect Unit to the ARC Plus Site.....	7
Manually Mapping PlusConnect Parameters	8
Setting up Labels, Limits and Alarms	10
Operation	10
Troubleshooting	10
Connection Errors.....	10
Getting Help.....	11
Warranty	12

Introduction

The PlusConnect™ BDI DPS-100D provides a connection between one and up to four BDI DPS-100D RF Power Measurement System and the ARC Plus transmitter remote control system. The PlusConnect reads transmitter parameters using SNMP (Simple Network Management Protocol) over an existing LAN, WAN, or Internet connection. The PlusConnect then forwards real-time data to the ARC Plus, also via LAN, WAN, or Internet. Monitor and control PlusConnect channels via:

- The front panel of the ARC Plus
- A web browser, using the built-in web interface on the ARC Plus
- Web-enabled mobile device, using the built-in mobile web interface on the ARC Plus
- PC, using optional AutoPilot® 2010 or AutoPilot® Plus software
- Telephone, using the optional ESI Enhanced Speech Interface for the ARC Plus

The PlusConnect is part of the Plus-X family of Ethernet I/O products designed for the ARC Plus.

Important! The PlusConnect operates in conjunction with an ARC Plus system. Be sure to complete configuration of the ARC Plus before adding the PlusConnect to the system.

Installation Note

Even though you may operate the ARC Plus and PlusConnect on different subnets, Burk Technology strongly recommends installing the PlusConnect on the same LAN as the ARC Plus. In a network failure, an ARC Plus can only continue to monitor and control a PlusConnect on the same LAN. If the network link between the units is not available, ARC Plus macros, alarm monitoring and telephone control will be unavailable for the PlusConnect unit.

Compatibility

PlusConnect Compatibility

The PlusConnect is capable of communicating with up to four individual BDI DPS-100Ds.

ARC Plus Compatibility

Before installing the PlusConnect, please verify that the ARC Plus firmware, AutoPilot software and AutoLoad Plus software versions are current. Updates are available at www.burk.com. The following are minimum software and firmware requirements

Software	Version
ARC Plus firmware	2.1.0
AutoLoad Plus software	2.0.0
AutoPilot Plus software	2.0.0
AutoPilot 2010 software	2.5.0

Unpacking

The PlusConnect BDI DPS-100D ships with the following:

- Manual
- PlusConnect unit
- Power cord
- 10' shielded CAT5 cable

Front Panel Indicators



Front panel of the PlusConnect unit

Indicator	State	Description
Power LED	On	Power is on
Power LED	Off	Power is off
Link LED	On (solid)	ARC Plus and transmitter connections are good
Link LED	Blinking	Transmitter connection is down


Link LED	Off	ARC Plus connection is down
----------	-----	-----------------------------

Hardware Configuration

This step will link the PlusConnect to a specific ARC Plus unit and will identify the transmitter to which the unit will be connected.

Important! This procedure will reset the PlusConnect to its default IP address: 192.168.0.100.

1. Connect your PC and the PlusConnect to the same LAN.
2. Assign your PC the IP address 192.168.0.1, with the subnet mask 255.255.255.0
3. Use a paper clip or similar small object to press the **Config** button on the PlusConnect unit. The power LED will blink when the unit is in configuration mode.
4. Open a telnet session to the PlusConnect at the address 192.168.0.100 (port 23). Using Windows, you can launch telnet by typing "telnet 192.168.0.100" from a command prompt.
5. When prompted, enter the default password for the PlusConnect: *password*.



```

C:\> Telnet 192.168.0.100
Burk Technology
PlusConnect BDI DPS-100D v1.0.10
Password:

```

6. Telnet will display the main menu.

```

c:\ Telnet 192.168.0.100
Burk Technology
PlusConnect BDI DPS-100D v1.0.10
Password: *****
Logged on successfully


1. Log Off
2. Set IP Address: 192.168.0.100
3. Set Subnet: 255.255.255.0
4. Set Gateway: 192.168.0.1
5. Set Telnet Port: 23
6. Configure DPS-100D #1
7. Configure DPS-100D #2
8. Configure DPS-100D #3
9. Configure DPS-100D #4
10. SNMP Poll period: 0.3
11. ARC Plus IP Address: 192.168.0.101
12. Plus-X Port: 45000
13. Set Password
14. Diagnostics
15. Update Firmware.
99. Save Configuration and Reboot.

```

To change a setting, enter the menu number for that setting and press <Enter>.

7. Enter the appropriate configuration settings for the following parameters:

#	Setting	Description
2	IP Address	The IP address you want to assign to the PlusConnect unit
3	Subnet	The subnet mask for your LAN
4	Gateway	The gateway for your LAN
6	Configure DPS-100D	Set IP Address, SNMP Port, Read & Write Community Strings
7	Configure DPS-100D	Set IP Address, SNMP Port, Read & Write Community Strings
8	Configure DPS-100D	Set IP Address, SNMP Port, Read & Write Community Strings
9	Configure DPS-100D	Set IP Address, SNMP Port, Read & Write Community Strings
10	SNMP Poll period	Specified in tenths of a second
11	ARC Plus IP Address	The IP address of your ARC Plus unit
12	ARC Plus Plus-X Port	The Plus-X port number configured on your ARC Plus (typically 45000)



```
c:\> Telnet 192.168.0.100

DPS-100D #1 Configuration
1. Set IP Address:                192.168.0.102
2. Set SNMP Port:                 161
3. Set SNMP Read Community String: public
4. Set SNMP Write Community String: private
5. Return to main menu
```

DPS-100D sub-menu for Option 6

8. Enter `gg` and press `<Enter>` to save your changes and reboot the PlusConnect.

SNMP Parameters

The default values for these entries are appropriate for most installations. If you have made specific changes to the SNMP functionality of your BDI DPS-100D, you should change the corresponding parameters using menu option 6, 7, 8, 9 or 10.

Setting the Password

Changing your password is strongly recommended. The PlusConnect password is used to access the telnet configuration menu. To change the password, use option #13: Set Password.

Uploading New Firmware

To upload new firmware to the PlusConnect, use option #15: Upload Firmware. When prompted to start the firmware upload, enter "Y" for yes. The system will respond with the following message:

```
To load firmware run:  
tftp [IP Address] put [firmware.hex]
```

Open a command prompt in Windows and type the specified command, replacing [IP Address] with the IP address of your PlusConnect unit, and [firmware.hex] with the file name of the new firmware file.

Once the TFTP process is complete, your unit will reboot and run the new firmware. You can confirm the upload was successful by opening a telnet session and observing the firmware version from the log on prompt.

For the latest firmware updates, visit www.burk.com.

Installation

After entering the configuration settings, you are ready to install the PlusConnect in its permanent location. Simply connect the PlusConnect unit to your LAN and power it on. The PlusConnect will automatically begin reading data from the transmitter.


Software Configuration

Now that the PlusConnect is installed on the network and connected to the transmitter, you are ready to add the PlusConnect to the ARC Plus using AutoLoad Plus. AutoLoad Plus is included with the ARC Plus, and may also be downloaded from www.burk.com.

Configuration involves:

- Adding the PlusConnect unit to the ARC Plus site
- Mapping PlusConnect parameters to unused ARC Plus channels

Adding the PlusConnect Unit to the ARC Plus Site



Adding a Plus-X device in AutoLoad Plus


In order for the ARC Plus to recognize the PlusConnect, the PlusConnect must be added to the site:

1. Open AutoLoad Plus and connect to the ARC Plus site to which you are adding the PlusConnect.
2. From the **Edit** menu, select **Plus-X Devices** to open the Plus-X device configuration dialog.
3. Click **New...** to add the PlusConnect to the site.
4. AutoLoad Plus will prompt you to select the device type. Select "PlusConnect BDI DPS-100D". You may optionally change the description for the PlusConnect. The description appears in AutoLoad Plus to identify each PlusConnect channel.
5. Enter the IP address and port number of the PlusConnect. These should be the same settings you used when you configured the PlusConnect using telnet.
6. Check the **Map default set of channels** box if you wish to automatically add the most commonly used PlusConnect parameters to the ARC Plus (recommended). This will replace unused ARC Plus channels with 19 PlusConnect status channels, 9 meters and 9 commands. **There must be 19 consecutive unused channels, including this starting channel.** You do *not* need to have additional Integrated Input Units and Integrated Command Relay Units in order to use these channels.

Important! PlusConnect channels take the place of normal I/O channels. If a metering input, status input, or command relay is connected to an ARC Plus channel and a PlusConnect parameter is subsequently mapped to that channel, the I/O channel will no longer be displayed.

7. Click **OK**.

Manually Mapping PlusConnect Parameters



Overriding channels in AutoLoad Plus

Even if you chose to map the default set of channels when you added the PlusConnect to the site, you may wish to map additional channels to the ARC Plus. The PlusConnect BDI DPS-100D transmitter provides access to many remote control parameters, all of which are selectable for display on the ARC Plus (provided there is sufficient unused channel capacity).

Mapping additional channels is accomplished in AutoLoad Plus by selecting the **Meter Channels**, **Status Channels** or **Commands** tab, as appropriate:

1. Within any of these tabs, click the **Override** button to change a channel's assignment from a traditional I/O channel to a Plus-X channel.
2. When the Override Channel dialog appears, select **Plus-X channel** and choose the Plus-X device from the list.
3. Select the PlusConnect channel you wish to use in place of this I/O channel.
4. Click **OK**.

Once mapped, the PlusConnect channel will appear on the front panel of the ARC Plus, in AutoPilot, on the ARC Plus web page, and will be accessible via the ESI.

Setting up Labels, Limits and Alarms

Labels, limits and alarms for PlusConnect parameters are set up in AutoLoad Plus. The process is the same as for limits and alarms of other ARC Plus channels. Refer to the ARC Plus manual for information on channel configuration.

Important! Because operation preferences vary so widely, no alarms are pre-configured within the PlusConnect channels. You must use AutoLoad Plus to set up alarms for the PlusConnect channels.

Operation

Once the PlusConnect parameters are mapped to ARC Plus channels using AutoLoad Plus, accessing the transmitter parameters is no different from any other ARC Plus channel. You may view channels using:

- The front panel of the ARC Plus
- The front panel of any ARC Plus configured for site-to-site operation with this site
- The built-in web interface
- A mobile device, via the built-in mobile web interface
- AutoPilot
- The ESI

For more information on using the ARC Plus to monitor and control the remote site, please see the ARC Plus Installation and Operation Manual.

Note that the PlusConnect channels are routed only through the ARC Plus unit specified during PlusConnect configuration. In order to access the transmitter by any means, the ARC Plus unit must be powered and connected to the network.

Troubleshooting

Connection Errors

If the PlusConnect is unable to communicate with the transmitter using SNMP, the Link LED on the front panel of the PlusConnect will blink. Check that both the PlusConnect and transmitter are connected to the network and configured properly.

If the network connection between the PlusConnect and ARC Plus is lost, the ARC Plus will log an alarm after three minutes of network failure. The PlusConnect Link LED will also turn off.

Note: PlusConnect events and errors are logged to the ARC Plus event list, which is accessible by the ARC Plus front panel and from AutoPilot.

Getting Help

For customer support, please email support@burk.com or call our direct customer support line at 978-486-3711. We will be glad to assist you. The customer support office is open Monday – Friday, 9AM to 5PM Eastern time.

Warranty

Burk Technology, Inc. warrants the PlusConnect BDI DPS-100D to be free of defects in materials and workmanship for a period of 24 months from the date of purchase. Equipment will be repaired or replaced at the option of Burk Technology and returned freight prepaid to the customer. Damage due to abuse or improper operation or installation of the equipment or caused by fire or flood or harsh environment is not to be covered by this warranty. Damage in shipping is not the responsibility of Burk Technology. A return authorization must be obtained before returning any equipment. Materials returned under this warranty must be shipped freight prepaid and insured in the original shipping carton or suitable substitute to Burk Technology, Inc., 7 Beaver Brook Road, Littleton, MA 01460. Repairs not covered under this warranty will be made at prevailing shop rates established by Burk Technology.

THE WARRANTY SET FORTH ABOVE IS IN LIEU OF ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. BURK TECHNOLOGY, INC. SHALL NOT BE LIABLE TO ANY PARTY FOR ANY INCIDENTAL, SPECIAL, INDIRECT OR CONSEQUENTIAL DAMAGES ARISING FROM THE USE OF THIS EQUIPMENT.